



NOTE:

ALL JOINT BONDING INSTALLATIONS USING STRANDED COPPER BONDING CABLES, MAINTAIN A MIN. OF 4 TO 6 INCHES OF SLACK BETWEEN THE BONDING CABLE POINTS OF ATTACHMENT.

JOINT BONDING DETAIL FOR EXISTING SCCP, PCCP, AND MLCP

NOT TO SCALE

PL12-12

031205

