



ITEM	DESCRIPTION
①	TAPPING SLEEVE
②	GATE VALVE
③	EXISTING COUPLING OR COLLAR
④	CONCRETE THRUST BLOCK
⑤	SUPPORT VALVE AS REQUIRED
⑥	EXISTING PIPE

NOTES

- CLEARANCE FROM A COLLAR OR PIPE JOINT SHALL BE A MINIMUM OF 2 FEET FROM THE EDGE OF TAPPING SLEEVE TO COLLAR OR PIPE JOINT. THE EXISTING PIPE SHALL BE EXPOSED SUFFICIENTLY TO ENSURE THAT SUCH MINIMUM CLEARANCE IS PROVIDED.
- TRENCH SHALL MEET ALL OSHA REQUIREMENTS.
- GATE VALVE TO BE TEMPORARILY SUPPORTED DURING THE WET TAP PROCESS.

EXCAVATION FOR WET TAPS

NOT TO SCALE

PL15-3

070703

