



NOTES:

1. CHANGES IN DIRECTION OF THE FIBER OPTIC CONDUIT BY MORE THAN 10 DEGREES SHALL BE ACCOMPLISHED USING PVC COATED RGS BENDS WITH A MINIMUM RADIUS OF 12 TIMES THE CONDUIT DIAMETER.
2. FOR ADDITIONAL TRENCH BACKFILL REQUIREMENTS SEE DETAIL

X
XXXX
3. FIBER OPTIC CONDUIT BEDDING SHALL BE SMOOTH AND STRAIGHT SO AS TO NOT INTRODUCE ANY FLEX OR BENDS IN THE CONDUITS.

FIBER OPTIC CONDUIT TRENCH LOCATION

NOT TO SCALE

PL06-2 061223

