


MATERIALS LIST:

- 6" FLG STL OUTLET FOR MLC STL PIPE, FLG TEE FOR DIP
- \bigcirc 6" FLG x FLG 90" DUCTILE IRON BEND
- (3) 6" RESTRAINED FLANGE ADAPTER
- $\bigcirc 4$ 6" FLG x PO OR FLG x MJ GATE VALVE WITH 2" OPERATING NUT
- $\boxed{5}$ 6" FLG x PE OR PE x PE DUCTILE IRON PC350, CUT TO FIT
- 6 6" DUCTILE IRON PC350 OR 6" PVC C900 PIPE
- $\overline{7}$ 6" MJ x MJ (RESTRAINED) 90' DUCTILE IRON BEND
- 8 6" AIR VALVE, FLANGED INLET
- 9 6" MUSHROOM VENT CAP WITH #22/24 STAINLESS STEEL MESH SCREEN
- 6" FLG BALL VALVE QUARTER TURN
- 6" FLG DUCTILE IRON SPOOL (9" LONG) WITH 2" THREADED PORT OR 2" SERVICE SADDLE
- (12) 2" CURB STOP, MALE THREADED, WITH LOCKING EYE
- 2" FEMALE THREADED BRONZE CAP
- (14) 5'-0" HIGH x 3'-0" OD STEEL ENCLOSURE
- (15) 5/8"-11NC BREAK-AWAY ZINC PLATED HEX HD BOLT, HEX NUT AND LOCKWASHER
- (16) VALVE BOX AND COVER

PROFILE VIEW



STANDARD INSTALLATION

