



NOTES:

1. A TYPICAL PIPE CLAMP INSTALLATION SHALL CONSIST OF 2 EACH 1/2"-13UNC x 8" LONG 316 STAINLESS STEEL ALLTHREAD ANCHOR RODS WITH 2 EACH NUTS PER ROD. THE NUTS SHALL CONFORM TO ASTM A563, GRADE A AND SHALL BE CHAMFERED ON BOTH ENDS.
2. EACH ANCHOR ROD SHALL BE SET INTO A 9/16" DIA. HOLE DRILLED INTO THE REINFORCED RESERVOIR WALL. EACH DRILLED HOLE SHALL BE CLEANED AS PER THE ANCHOR MANUFACTURER'S RECOMENDATIONS. THE RODS SHALL BE SET IN EPOXY. THE RODS AND EPOXY SHALL BE AS MANUFACTURED BY HILTI OR AN APPROVED EQUAL.
3. ALL CLAMPS SHALL BE MADE OF 316 STAINLESS STEEL.

PIPE CLAMP

NOT TO SCALE

RM03-2 070803

