



NOTES:

1. PAINT SHALL BE NSF 61/600 STANDARD APPROVED COPOLYMER, SUITABLE FOR CONCRETE APPLICATION WITH CONTINUOUS SUBMERSION.
2. CONCRETE COLUMNS AND WALL PREPARATION SHALL BE IN ACCORDANCE WITH THE PAINT MANUFACTURER RECOMMENDATIONS.
3. EACH COLUMN REQUIRES ONE STENCILED ALPHA CHARACTER AND ONE OR TWO NUMERIC CHARACTERS FACING TOWARDS THE RESERVOIR WALL WITH THE ACCESS HATCH STAIRWAY AND ON THE OPPOSITE SIDE OF THE COLUMN.
4. COLUMN ROW IDENTIFICATION IS REQUIRED ON THE RESERVOIR WALL AT THE EXTENSION OF EVERY COLUMN ROW.
5. PAINT COLUMN ROW CHARACTERS 5'-0" FROM THE BASE OF THE COLUMN, AND BASE OF WALL.

**COLUMN ROW IDENTIFICATION**

