



**NOTES:**

1. THE ASTERISK (\*) REFERS TO A SEQUENTIAL NUMBER FOR THE PUMPS IN THE PUMP STATION.
2. THE 95% CLOSED LIMIT SWITCH IS OPEN WHEN THE DISCHARGE VALVE IS 95-100% CLOSED.
3. P&ID REFERENCE DRAWINGS XXX (IT04-17)
4. PLC REFERENCE DRAWINGS XXX AND XXX (IT06-8, IT06-14)  
(NOTE TO ENGINEER: THIS SCHEMATIC IS FOR ZONE PUMPS ONLY)
5. # - REFER TO PLC DRAWINGS FOR WIRE NUMBERS, TERMINAL NUMBERS, AND PRINT NUMBER.

TYPICAL RVAT MOTOR STARTER WITH GE 469 MPR FOR 400 - 900 HP  
AT 4160 VOLTS, 3 DIA, 60HZ SCHEMATIC DIAGRAM II

NOT TO SCALE

E14-48 021522

