



- NOTES:**
1. VERIFY ALL TERMINATIONS TO EXISTING DEVICES.
 2. PROVIDE TERMINATION RESISTORS AND DEVICE CONFIGURATION AS REQUIRED TO ELIMINATE SIGNAL NOISE IN ACCORDANCE WITH RS485 STANDARDS.