



ALL HEX PLUGS ARE TO BE FLUSH WITH SURFACE PENETRATED. SPARE CONDUITS (OR TEMPORARILY UNUSED CONDUITS) SHALL BE THREADED WITH A HEX FLUSH PLUG INSTALLED SO AS TO NOT CAUSE A TRIP HAZARD OR ALLOW THE INFILTRATION OF CONTAMINANTS INTO THE CONDUIT. IF FOR ANY REASON THE CONDUIT IS NOT FLUSH WITH THE SURFACE PENETRATED THE CONTRACTOR SHALL EITHER CUT OFF OR EXTEND THE CONDUIT TO FULFILL THE FINISHED FLUSH REQUIREMENT. AS A MINIMUM, TO CORRECT ANY FLUSH PLUG CONDUIT INSTALLATIONS THE CONTRACTOR MAY BE REQUIRED AT HIS EXPENSE TO: JACK-HAMMER AND REPOUR CONCRETE; REMOVE AND REINSTALL MASONRY; REFINISH GYPSUM; PAINT; GROUT; RELOCATE EQUIPMENT; PROVIDE TEMPORARY FACILITIES; REROUTE CONDUITS.

## CONDUIT RISER

NOT TO SCALE

E03-1

061119

