



TOP VIEW

NOTE:

WALL BRACKET SHALL BE BUILT OF 1/4" THICK STAINLESS STEEL PLATE. BRACKET PLATES, BOTH TOP AND BOTTOM, SHALL BE SUFFICIENTLY LONG TO ALLOW CABINET TO SWIVEL WITHOUT ANY INTERFERENCES.

HYPOCHLORITE LEVEL DISPLAY PANEL

NOT TO SCALE

E11-3 062419

