



DETAIL A

NOTES:

- 1" STAINLESS STEEL BANDS AND BINDER SEAL. INSTALL BANDS 13' ABOVE FINISHED GRADE SO CAMERA IS A MIN OF 12' ABOVE FINISHED GRADE.
- DRILL AND DEBURR 2-1" HOLES IN POLE FOR POWER AND COMMUNICATION, INSTALL RUBBER GROMMET AND SEAL HOLES.
- THE DISTRICTS SECURITY SYSTEM VENDOR TO PROVIDE ALL CABLING FOR SECURITY COMPONENTS.
- LUMINAIRE POWER CABLES SHALL BE SHEILDEN INSIDE THE POLE TO PREVENT EMI INTERFERENCE WITH SECURITY SYSTEM CABLES.
- NOTE TO ENGINEER: POLE HEIGHT AND POLE SHAPE/COLOR PER SPECIFIC CONTRACT REQUIREMENTS.

