



NOTES:

1. EXCAVATE AND BACKFILL (12" MIN) AROUND ALL SIDES AND BOTTOM OF PULLBOX PER SPECS SEC 31 20 00.
2. ALL UNDERGROUND GROUNDING CONNECTORS AND TAPS TO USE EXOTHERMIC CONNECTIONS. THIS INCLUDES BUT IS NOT LIMITED TO CONNECTIONS IN CONCRETE, PULL BOXES, BELOW GRADE, WHERE INDICATED ON DRAWINGS, OR WHERE REQUIRED BY ENGINEER.
3. INSTALL DUCT PLUGS AND PULL TAPE IN ALL EMPTY CONDUITS.

PULLBOX WITH SIDE PENETRATIONS

NOT TO SCALE

E02-3

101619

