



- NOTES:
1. THE ASTERISK (*) REFERS TO A SEQUENTIAL NUMBER FOR THE PUMPS IN THE PUMP STATION.
 2. THE 95% CLOSED LIMIT SWITCH IS OPEN WHEN THE DISCHARGE VALVE IS 95-100% CLOSED.
 3. P&ID REFERENCE DRAWING XXX (IT04-13)
 4. PLC REFERENCE DRAWINGS XXX AND XXX (IT06-9, IT06-13)
(NOTE TO ENGINEER: THIS SCHEMATIC IS FOR ZONE PUMPS ONLY)
 5. # - REFER TO PLC DRAWINGS FOR WIRE NUMBERS, TERMINAL NUMBERS, AND PRINT NUMBER.

TYPICAL FVNR MOTOR STARTER WITH OLVD'S FOR 1/2 - 75 HP AT 480 VOLTS, 3 DIA, 60HZ SCHEMATIC DIAGRAM

NOT TO SCALE

E14-8 021522

