



**NOTES:**

1. COORDINATE WITH THE OWNER FOR FINAL PLACEMENT OF SUSPENDED SENSOR RELATIVE TO TANK TOP SURFACE.
2. TERMINATE SENSOR CABLE IN CONDUIT FITTING ABOVE TANK AT CEILING. FINAL LENGTH DETERMINED AT PLACEMENT.
3. SEE IT03-8 FOR SENSOR/DISPLAY/PLC WIRING DIAGRAM.

**HYPOCHLORITE TANK RADAR LEVEL TRANSMITTER DETAIL**

NOT TO SCALE

IT03-9

120621

