



NOTES:

- SCADA INSTRUMENT LOOP NUMBERS SHALL BE PRECEDED BY THE FOLLOWING:
 XXXXSITE NAME_ [NOTE TO ENGINEER: ENTER ASSIGNED ZONE NUMBER FOR XXXX, AND ASSIGNED SITE NAME]
- [NOTE TO ENGINEER: IF SODIUM HYPOCHLORITE PUMPS ARE PIPED IN PARALLEL, CONCURRENT OPERATION IS PROHIBITED.]

SODIUM HYPOCHLORITE STORAGE AND FEED SYSTEM

**NAOCL STORAGE AND FEED SYSTEM
 PROCESS AND INSTRUMENTATION DIAGRAM**

NOT TO SCALE 1104-6 041907