



NOTES:

1. FOR LEVEL TRANSMITTER, REFER TO SPECIFICATIONS (RED LION, PRECISION DIGITAL, NEWPORT OR OWNER APPROVED EQUAL).
2. HIGH LEVEL LED MAY BE DRIVEN BY PLC OUTPUT OR BY 24VDC POWERED DISPLAY EQUIPPED WITH ADJUSTABLE CONTACT OUTPUT.
3. LEVEL DISPLAY MAY BE LOOP POWERED OR EXTERNALLY POWERED DEPENDING ON CURRENT. PROVIDE LARGE NUMERAL 3 TO 4 DIGIT DISPLAY: 0 TO 100% AND MAY INCLUDE VERTICAL BARGRAPH. MIRRORRED ANALOG OUTPUT AND ADJUSTABLE DISCRETE OUTPUT.
4. UNIT MUST BE SUITABLE FOR FOR OPERATION IN 140°F AMBIENT, BE VISIBLE IN DIRECT SUNLIGHT AND RESIST FADING.

DISINFECTION TANK LEVEL WIRING DIAGRAM

NOT TO SCALE

IT03-8

120821

