



NOTES:

1. QUICK COUPLING VALVE ASSEMBLIES SHALL BE INSTALLED AT A DISTANCE OF 500(±) FOOT INTERVALS THROUGH THE TOTAL LENGTH OF THE LINE OR A MINIMUM OF TWO PER PROJECT.
2. FLUSH VALVE ASSEMBLY SHALL BE INSTALLED AT THE END OF EACH ZONE WATER LINE.

IRRIGATION CONTROL PLAN

NOT TO SCALE

LS-04

071003

