



NOTES:

1. ATMOSPHERIC VACUUM BREAKERS SHALL BE INSTALLED APPROXIMATELY 6" ABOVE FINISHED GRADE AND ABOVE A SUFFICIENT NUMBER OF SPRINKLER HEADS CLOSEST TO THE VACUUM BREAKER SO THAT AT NO TIME WILL IT BE SUBJECTED TO BACK PRESSURE OR DRAINAGE.
2. CLOSE NIPPLES SHALL NOT BE USED.
3. ALL FITTINGS, INCLUDING THE ATMOSPHERIC VACUUM BREAKER SHALL NOT BE SMALLER SIZE THAN THE VALVE.

BACKFLOW PREVENTER ATMOSPHERIC VACUUM BREAKER

NOT TO SCALE

LS-33

060506

