



NOTES:

1. 4'-6" x 8'-6" x 6'-6" NOMINAL INSIDE DIMENSIONS PRECAST MANHOLE WITH 30" COVER.
2. DESIGN LOAD: H-20 FULL TRAFFIC WITH 13 INCHES TO 4 FEET SOIL COVER TO TOP OF SLAB. WATER TABLE BELOW BASE OF VAULT.
3. ENTIRE VAULT ASSEMBLY AND CONDUIT INSTALLATION SHALL BE CLEAN AND DRY AT TIME OF ACCEPTANCE.
4. BACKFILL AROUND VAULT ASSEMBLY IN ACCORDANCE WITH SPEC SEC 31 20 00.
5. FINAL MANHOLE FRAME ADJUSTMENT AND CONCRETE COLLAR INSTALLATION REQUIREMENTS, SEE DETAIL  (PL08-4)
6. INCLUDE CABLE RACKING WITH EACH MANHOLE FOR FIELD INSTALLATION.

APPROXIMATE LOCATIONS OF FIBER OPTIC VAULTS		
PROJECT / VAULT NO.	DWG. NO.	STATION
XXXXX-1	XXX	XX+XX.XX
XXXXX-2	XXX	XX+XX.XX
XXXXX-3	XXX	XX+XX.XX
XXXXX-4	XXX	XX+XX.XX
XXXXX-5	XXX	XX+XX.XX
XXXXX-6	XXX	XX+XX.XX
XXXXX-7	XXX	XX+XX.XX
XXXXX-8	XXX	XX+XX.XX
XXXXX-9	XXX	XX+XX.XX

FIBER OPTIC VAULT ASSEMBLY

SCALE: 1/4" = 1'-0"

PL06-3 113025

