

WATER QUALITY COMPONENT DESCRIPTIONS

XX	DESCRIPTION
1	HOUSING GAP
2	MAIN SAMPLING VALVE
3	BRASS HOUSING
4	1" x 3/4" BALL ANGLE METER STOP W/PADLOCK WING W/O LEVEL HANDLE
5	BRASS BASE
6	3/4" BRASS METER NUT (W/GASKET)
7	METER SETTER (COPPER)
8	#3 REBAR IN CONCRETE COLLAR IF NO SIDEWALK
9	1" METER BOX INSTALLED AT FUTURE FINISHED GRADE (WITHIN 1")
10	3/4" METER
11	DUAL CHECK VALVE BACKFLOW PREVENTOR
12	THROTTLING VALVE
13	PROBE ROD W/UNTHREADED SPIGOT (MODEL 1500)
14	VALVE KEY
15	1" COPPER TUBING
16	1" SERVICE SADDLE (PVC OR DIP)
17	1" CORP STOP
18	INSULATING FLANGE. SEE DETAIL [] ON DWG []
19	"LVVWD SAMPLING STATION" MARKED ON LID
20	6" FLANGED OUTLET WITH 6" FLANGED GATE VALVE
21	6" x 1" THREADED BRASS REDUCING FLANGE
22	4" FLANGED OUTLET WITH 4" x 1" THREADED BRASS REDUCING FLANGE

(PL05-4)