



NOTES:

1. TORQUE BOLTS PER INSULATING FLANGE SET MANUFACTURERS RECOMMENDATIONS (TYP).
2. VAULT LOCATIONS: ASTM F593, SS TYPE 316 BOLT WITH ASTM A563 NUT, XYLAN 1000 SERIES COATING.

BURIED OR EXPOSED LOCATIONS: ASTM A307 BOLT - UNC THREADS, WITH ASTM A563 NUT, ZINC COATED.

INSULATING FLANGE SET DETAIL

NOT TO SCALE

PL05-4

072315

