



NOTES:

1. PIPE REPLACEMENT ONLY REQUIRED WHEN REPAIRING DAMAGED PIPE. ALL ATTEMPTS MUST BE MADE TO PROTECT PIPE IN PLACE.
2. CONTRACTOR SHALL MAINTAIN CONTINUOUS SEWER SERVICE TO CUSTOMERS. SEWER LATERALS DAMAGED DURING CONSTRUCTION SHALL BE REPAIRED IMMEDIATELY BY THE CONTRACTOR AT THEIR EXPENSE. CONTRACTOR SHALL NOTIFY AFFECTED CUSTOMERS.
3. INSTALL SAND BACKFILL AROUND WATER SERVICE LATERALS PRIOR TO INSTALLATION OF CEMENT SLURRY IN TRENCH.
4. MAINTAIN POSITIVE SLOPE ON SEWER LATERAL.
5. SEWER LATERALS ARE PRIVATELY OWNED AND CCWRD BEARS NO RESPONSIBILITY FOR REPAIRS, MODIFICATIONS OR OTHERWISE.

EXISTING PRIVATE SEWER SERVICE LATERAL REPAIR

NOT TO SCALE

PL02-9 010522

