



**GENERAL NOTES FOR SAFETY AND COMPLIANCE SIGNS:** MS02-1

- INDOOR SIGNS SHALL BE MADE OF RIGID POLYETHYLENE PLASTIC .055" THICK WITH 4 EACH 3/16" DIA MOUNTING HOLES.
- OUTDOOR SIGNS SHALL BE MADE OF ALUMINUM .040" THICK WITH 3/16" DIA HOLES, OR STEEL 18 GAUGE THICK WITH 3/8" DIA HOLES-CENTERED (SEE DETAILS).
- OUTDOOR STEEL OR ALUMINUM SIGNS SHALL BE SURFACE MOUNTED TO WALLS, DOORS, CABINETS AND STEEL CHANNEL SIGN POSTS (STEEL SIGNS ONLY). ALL SCREW AND BOLTED FASTENERS SHALL BE NON-CORROSIVE.
- SIGN COATINGS SHALL BE BAKED ENAMEL AND VANDAL-RESISTANT. COLORS SHALL BE IN ACCORDANCE WITH ANSI STANDARDS OR AS APPROVED BY THE ENGINEER.
- ALL SIGNS SHALL BE INSTALLED PLUMB AND LEVEL.
- AN ADDITIONAL SIGN POST IS REQUIRED FOR SIGNS GREATER THAN 20 INCHES IN WIDTH.

**FOR EXAMPLE ONLY**

**NOTES:**

- THE CONTENTS OF THIS DRAWING WERE CREATED TO PROVIDE A GRAPHIC REPRESENTATION OF LVWD AUTOCAD STANDARD REQUIREMENTS AND EXPECTATIONS FOR SAFETY SIGNAGE LOCATION PLANS OF FACILITIES SITES, ASSOCIATED BUILDINGS AND UNDERGROUND VAULT STRUCTURES.
- ALL TYPES OF INFORMATION ON THIS DRAWING ARE REQUIRED TO BE PROVIDED AS SHOWN FOR THE PROJECT SUBMITTAL TO BE ACCEPTED AND APPROVED (TYP).

**LAS VEGAS VALLEY WATER DISTRICT**

SPACE FOR CONSULTANT LOGO.

NAME AND ADDRESS

VERIFY SCALE: 1/2" = 1'-0"

DATE REPRESENTS ORIGINAL INCHES ON ORIGINAL

**EXAMPLE CONTRACT STANDARDS**

SAFETY AND COMPLIANCE SIGNAGE LOCATION PLANS FOR FACILITIES SITES AND BUILDINGS

SCALE AS NEEDED

DRAWN BY: XX/XX/XX

CHECKED BY: XX/XX/XX

RECOMMENDED BY: DATE

ACCEPTED BY: DATE

ENGINEER'S STAMP

CONTRACT NUMBER

**CXXX**

DRAWING NUMBER XXX

SHEET XX OF XXX