

## SECTION 3 – CLASSES OF SERVICE

All services installed by or for the BBWD shall be classified as domestic, private fire, combined, construction, or supplemental for billing purposes.

### 3.1 Domestic Service

“Domestic service” shall mean a service connection through which water is obtained for all purposes exclusive of fire protection, or construction water including commercial, industrial and irrigation.

### 3.2 Private Fire Service

“Private Fire Service” shall mean a service connection through which water is available on private property for fire protection exclusively. Private fire service shall be equipped with a BBWD approved double check detector assembly (DCDA), or Reduced Principal Detector Assembly (RPDA), **per NAC 445A**

### 3.3 Combined Service

“Combined Service” shall mean a single service connection through which water is delivered for the dual purpose of private fire service and domestic service.

### 3.4 Construction Water

Construction Water shall mean metered water delivered for construction purposes including, but not limited to, compaction and dust control. Construction water is not permitted for domestic or fire suppression use.

- a Includes permanent or non-permanent, metered connections for delivery of water for use during construction of new development, additions to existing improvements, sand and gravel operations, and other construction uses, such as grading and compaction, paving, and dust control.
- b Construction services may not be used to avoid installation of a permanent water service connection for permanent irrigation, long-term dust suppression, domestic service, or private fire service.

Water from construction sites is prohibited from flowing continuously into public streets, pathways, roadways, and sidewalks.

- c Raw water consumption will be charged in accordance with the adopted Construction Water rate schedule. The user shall:
  1. Provide a written request to the BBWD for use of raw water. The request must include the type of use and location, rate, and frequency of the proposed diversion, plus any additional information necessary for BBWD to request and obtain approval from the Bureau of Reclamation for the raw water diversion.
  2. Provide approved plans for raw water pumping, metering approval and transmission facilities to BBWD as well as other information deemed necessary for the application and review of the request.

**3.5 Supplemental Service**

Supplemental Service shall mean a service connection or connections to property that is also served by another source of supply, such as a well or non-potable system. A supplemental service connection shall include an approved backflow prevention assembly. This section shall not apply to properties that are served by a domestic well, as identified in NRS 534.