

LAS VEGAS VALLEY WATER DISTRICT

2026 WATER QUALITY SUMMARY

SUBSTANCE	Average Value	MCL	UNITS		SUBSTANCE	Average Value	MCL	UNITS
ALKALINITY, as HCO ₃	137	N/A	ppm		1,2,4-TRICHLOROBENZENE	<0.50	70	ppb
ALPHA EMITTERS	4.3	15	pCi/L		1,1,1-TRICHLOROETHANE	<0.50	200	ppb
ALUMINUM	<0.005	0.2	ppm	(1)	1,1,2-TRICHLOROETHANE	<0.5	5	ppb
ANTIMONY	<0.4	6	ppb		1,1-DICHLOROETHYLENE	<0.5	7	ppb
ARSENIC	1.7	10	ppb		1,2 DICHLOROPROPANE	<0.5	5	ppb
ASBESTOS	<0.2	7	MFL		1,2-DICHLOROBENZENE	<0.50	600	ppb
BARIUM	0.1	2	ppm		1,2-DICHLOROETHANE	<0.5	5	ppb
BERYLLIUM	<0.4	4	ppb		1,4-DICHLOROBENZENE	<0.50	75	ppb
BROMATE	3.1	10	ppb		2,3,7,8-TCDD (DIOXIN)	<0.005	0.03	ppt
BROMIDE	<0.020	N/A	ppm		2,4-D	<0.10	70	ppb
CADMIUM	<0.5	5	ppb		ALACHLOR	<0.05	2	ppb
CALCIUM	75	N/A	ppm		ATRAZINE	<0.05	3	ppb
CHLORIDE	98.6	400	ppm	(1)	BENZENE	<0.5	5	ppb
CHLORINE RESIDUAL, FREE	0.99	4.0	ppm	(2)	CARBOFURAN	<0.50	40	ppb
CHROMIUM, TOTAL	<3.0	100	ppb		CARBON TETRACHLORIDE	<0.5	5	ppb
COLIFORM, TOTAL	0.1	5	percent positive per month		CHLORDANE	<0.1	2	ppb
COLOR, TRUE	3	15	PCU	(1)	CHLOROENZENE	<0.50	100	ppb
CONDUCTIVITY	923	N/A	µS/cm		cis-1,2-DICHLOROETHYLENE	<0.50	70	ppb
COPPER	3.9	1.0	ppm	(1)	DALAPON	<1.0	200	ppb
CYANIDE, FREE	<25	200	ppb		DI (2-ETHYLHEXYL) ADIPATE	<0.60	400	ppb
FLUORIDE ⁽³⁾	0.65	4.0	ppm		DI (2-ETHYLHEXYL) PHTHALATE	<0.6	6	ppb
		2	ppm	(1)	DIBROMOCHLOROPROPANE	<0.02	0.2	ppb
HALOACETIC ACIDS (Total Regulated)	44	60	ppb		DICHLOROMETHANE	<0.5	5	ppb
HARDNESS, TOTAL	280	N/A	ppm		DINOSEB	<0.2	7	ppb
	16		gpg		DIQUAT	<0.40	20	ppb
IRON	<0.05	0.6	ppm	(1)	ENDOTHALL	<8.0	100	ppb
LEAD	<0.0003	N/A	ppm		ENDRIN	<0.01	2	ppb
MAGNESIUM	24	150	ppm	(1)	ETHYLBENZENE	<0.50	700	ppb
MANGANESE	<0.005	0.1	ppm	(1)	ETHYLENE DIBROMIDE	<0.01	0.05	ppb
MBAS	<0.1	0.5	ppm	(1)	GLYPHOSATE	<6.0	700	ppb
MERCURY	<0.2	2	ppb		HEPTACHLOR EPOXIDE	<0.01	0.2	ppb
MOLYBDENUM	<0.0050	N/A	ppm		HEPTACHLOR (H-34, HEPTOX)	<0.01	0.4	ppb
NICKEL	<0.0050	N/A	ppm		HEXACHLOROBENZENE	<0.05	1	ppb
NITRATE (as NITROGEN)	0.56	10	ppm		HEXACHLOROCYCLOPENTADIENE	<0.050	50	ppb
NITRITE (as NITROGEN)	<0.02	1	ppm		LINDANE	<0.01	0.2	ppb
ODOR	<1	3	TON	(1)	METHOXYCHLOR	<0.050	40	ppb
ORTHO PHOSPHATE, as PO ₄	0.078	N/A	ppm		MTBE	<0.5	N/A	ppb
PERCHLORATE	0.70	N/A	ppb		OXAMYL (VYDATE)	<0.50	200	ppb
pH	7.8	6.5 - 8.5	pH units	(1)	PAHs (benzo(a)pyrene)	<0.02	0.2	ppb
POTASSIUM	5.0	N/A	ppm		PENTACHLOROPHENOL	<0.04	1	ppb
RADIUM 226 AND RADIUM 228 (Combined)	<1	5	pCi/L		PICLORAM	<0.10	500	ppb
SATURATION INDEX	0.25	N/A	N/A		POLYCHLORINATED BIPHENYLS	<0.1	0.5	ppb
SELENIUM	2.8	50	ppb		SILVEX (2,4,5 - TP)	<0.10	50	ppb
SILICA	8.3	N/A	ppm		SIMAZINE	<0.05	4	ppb
SILVER	<0.005	0.1	ppm	(1)	STYRENE	<0.50	100	ppb
SODIUM	89	N/A	ppm	(4)	TETRACHLOROETHYLENE	<0.5	5	ppb
SULFATE	209	500	ppm	(1)	TOLUENE	<0.50	1000	ppb
TEMPERATURE	19	N/A	deg C		TOXAPHENE	<0.5	3	ppb
THALLIUM	<0.2	2	ppb		trans-1,2 DICHLOROETHYLENE	<0.50	100	ppb
TOTAL DISSOLVED SOLIDS	591	1000	ppm	(1)	TRICHLOROETHYLENE	<0.5	5	ppb
TRihalOMETHANES (Total)	72	80	ppb		VINYL CHLORIDE	<0.5	2	ppb
TURBIDITY (maximum value)	<0.3	N/A	NTU	(4)	XYLENES	<0.50	10,000	ppb
URANIUM	3.8	30	ppb					
VANADIUM	<0.0050	N/A	ppm					
ZINC	0.070	5.0	ppm	(1)				

- (1) State of Nevada Secondary Standard
- (2) MRDL
- (3) Fluoridation Started March 2000
- (4) Treatment technique requirement

MCL - Maximum Contaminant Level Set by EPA
MFL - Million Fibers per Liter, with fiber length > 10 microns
N/A - Not applicable, No Standard Set
NTU - Nephelometric Turbidity Unit
pCi/L - picocuries per liter
ppb - parts per billion
ppm - parts per million
ppt - parts per trillion
µS/cm - Micro Siemens per centimeter
PCU - Platinum Cobalt Units
gpg - grains per gallon
TON - threshold odor number
MRDL - Maximum Residual Disinfectant Level
"<" - less than